

Date : 04/04/2023
Project No : 2021C060
Client Company : Pulte Group
Arrival Time : 04/04/2023
Onsite Hours :

ASEC Report ID : 58634
Name of the Project : Suncity - Peachtree
Project Location : Griffin, GA
Weather :
Departure Time : 04/04/2023
ASEC Technician Name : Russell Hendrix

As requested, the site was visited by our AS Engineering and Consulting (ASEC) representative noted above, for the purpose of providing quality control inspection and testing services, visual observation techniques were employed to assure compliance with project drawing/specifications.

A request was made for a footing inspection for Lot #65 pod 15 and Lot #78 pod 15. A request to the foreman (Robert) was made to demuck both lots. All rebar appeared to be placed as per project specifications as to size, spacing and quantity. Probing with a 3/8-inch diameter probe red and DCP testing was conducted and was found to meet a soil bearing pressure of 2000 psf.



Kenneth Mosman

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.