

Date : 07/08/2023  
Project No : 2021C060  
Client Company : Pulte Group  
Arrival Time : 07/08/2023 17:00  
Onsite Hours : 01:30

ASEC Report ID : 60238  
Name of the Project : Suncity - Peachtree  
Project Location : Griffin, GA  
Weather : Sunny  
Departure Time : 07/08/2023 18:30  
ASEC Technician Name : Ramchandra Mogulla

The undersigned ASEC representative verified the current positioning and its proximity to the proposed turn down slab from the installed sewer line. The property address is noted as (Lot #118-13) 132 Alcovy Court, Griffin, GA.

Visual observation techniques were employed to evaluate work in-place for general compliance with the Project Plans, Specifications, Codes and Standards and Material Submittals.

- The Project representative Zack informed about the objection the county official had with respect to the proximity of the sewer line to the adjacent turndown slabs.
- Measurements were taken of the current excavations to verify the objection that the sewer line may be in the zone of influence of the footing.
- The attached schematic is an attempt to the measurements taken in the field.
- Based on the measurements taken and as shown in the attached sketch and or experience with such structures we believe the sewer line and its excavation are outside the zone of influence of the footing and slab.

We appreciate the opportunity to be of help and will be happy to discuss our recommendations. We also welcome the opportunity to provide additional services necessary to complete this project. We look forward to serving as your geotechnical engineer in the future.



**Ramchandra R. Mogulla**  
GA P.E. 036021  
Senior Engineer

*Kenneth Mosman*

**Kenneth Mosman**

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without

Date : 07/08/2023  
Project No : 2021C060  
Client Company : Pulte Group  
Arrival Time : 07/08/2023 17:00  
Onsite Hours : 01:30

## Daily Field Report

ASEC Report ID : 60238  
Name of the Project : Suncity - Peachtree  
Project Location : Griffin, GA  
Weather : Sunny  
Departure Time : 07/08/2023 18:30  
ASEC Technician Name : Ramchandra Mogulla

---

written approval from AS Engineering and Consulting LLC.