

Date : 05/19/2026
Project No : 2021C060
Client Company : Pulte Group
Arrival Time : 05/19/2026 10:00
Onsite Hours : 04:00

ASEC Report ID : 94548
Name of the Project : Suncity - Peachtree
Project Location : Griffin, GA
Weather : Sunny
Departure Time : 05/19/2026 14:00
ASEC Technician Name : Sean Willett

As requested, the site was visited by our AS Engineering and Consulting (ASEC) representative for the purpose of providing quality control inspection and testing services. Visual observation techniques were employed to verify compliance with project drawing/specifications, applicable codes, and materials submittals. The following observations were observed on site this day.

Our ASEC representative was on site as requested by the contractor (Pulte) for the observation/testing of footings. The footing passed probe rod testing. Plastic was placed and rebar was tied. DCP testing was conducted. 4526

We appreciate the opportunity to be of service to you on this project. If you have any questions regarding this report, please feel free to contact us. We will be more than happy to discuss it with you.



4526





AS Engineering
and Consulting LLC

Daily Field Report

Date : 05/19/2026
Project No : 2021C060
Client Company : Pulte Group
Arrival Time : 05/19/2026 10:00
Onsite Hours : 04:00

ASEC Report ID : 94548
Name of the Project : Suncity - Peachtree
Project Location : Griffin, GA
Weather : Sunny
Departure Time : 05/19/2026 14:00
ASEC Technician Name : Sean Willett

A handwritten signature in black ink that reads 'Kenneth Mosman'.

Kenneth Mosman

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.