

ASEC Report ID : 53270
Name of the Project : Estates at Old Friendship
Project Location : Buford, GA
Weather : 55 drizzle
Departure Time : 02/17/2022
ASEC Technician Name : Russell Hendrix

Date : 03/09/2022
Project No : 2021C082
Client Company : CCG Constructors LLC (Century)
Arrival Time : 02/17/2022
Onsite Hours :

The site was visited by the undersigned AS Engineering and Consulting (ASEC) representative for the purpose of providing quality control inspection and testing services. Visual observation techniques were employed to assure compliance with project drawings/specifications, applicable codes, and materials submittals. The following observations were made on site today:

Upon arrival, our representative observed tandem dump trucks importing soil to be used for the main roadway fill (Friendship Falls Way). It was noted the area of the proposed road was pumping & rutting as dump trucks traversed the area. Lifts of 12 inches were placed and compacted with a Bomag BW 211. The high moisture levels of the area were discussed with Dennis the on-site grading foreman.

It was noted that a pump was being utilized to drain water from one section of the site to the detention pond.


Kenneth Mosman

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.