

ASEC Report ID : 53265  
Name of the Project : Estates at Old Friendship  
Project Location : Buford, GA  
Weather : 40 Cloudy  
Departure Time : 02/16/2022  
ASEC Technician Name : Russell Hendrix

Date : 03/09/2022  
Project No : 2021C082  
Client Company : CCG Constructors LLC (Century)  
Arrival Time : 02/16/2022  
Onsite Hours :

---

The site was visited by the undersigned AS Engineering and Consulting (ASEC) representative for the purpose of providing quality control inspection and testing services. Visual observation techniques were employed to assure compliance with project drawings/specifications, applicable codes, and materials submittals. The following observations were made on site today:

Approximately eight dump trucks were used to import soils to be used as fill for the proposed main road Friendship Falls Way & side road Friendship Creek Drive. Materials were placed in 12-inch lifts and compacted using a Bomag BW 211 vibratory roller. See attached Density report. Ground movement (pumping and rutting) was noted as vehicles passed over the compacted areas. This was discussed with Dennis the grading foreman on site.

  
**Kenneth Mosman**

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.