

ASEC Report ID : 53242
Name of the Project : Estates at Old Friendship
Project Location : Buford, GA
Weather : 35 sunny
Departure Time : 02/15/2022
ASEC Technician Name : Russell Hendrix

Date : 03/09/2022
Project No : 2021C082
Client Company : CCG Constructors LLC (Century)
Arrival Time : 02/15/2022
Onsite Hours :

The site was visited by the undersigned AS Engineering and Consulting (ASEC) representative for the purpose of providing quality control inspection and testing services. Visual observation techniques were employed to assure compliance with project drawings/specifications, applicable codes, and materials submittals. The following observations were made on site today:

Upon arrival, our representative observed eight dump trucks were being used to deliver material used for fill. The soil types appeared mixed, some with rock fragments. This soil was being used for lifts on the main road from Sta 16+00 to Sta 18+00. Lifts were placed approximately 12 inches and compacted with a Bomag sheep-foot compactor. Please see attached density report.

It was observed that the ground displayed some deflection as the dump trucks traversed this area. This was discussed with Dennis the grading foreman.


Kenneth Mosman

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.