

ASEC Report ID : 53038
Name of the Project : Estates at Old Friendship
Project Location : Buford, GA
Weather : 34 sunny
Departure Time : 01/26/2022 11:30
ASEC Technician Name : Russell Hendrix

Date : 02/04/2022
Project No : 2021C082
Client Company : CCG Constructors LLC (Century)
Arrival Time : 01/26/2022 08:30
Onsite Hours : 03:00

The site was visited by the undersigned AS Engineering and Consulting (ASEC) representative for the purpose of providing quality control inspection and testing services. Visual observation techniques were employed to assure compliance with project drawings/specifications, applicable codes, and materials submittals. The following observations were made on site today:

A meeting was held with Dennis the foreman of the grading crew. It was determined that on January 27th a new soil type would be delivered to provide material for lifts under the proposed road. A proof-roll was conducted. One area at Station 15+00 displayed some pumping and/or rutting. A call was made to our ASEC representative Ken Mosman to discuss the high moisture level issues with the current on-site sandy soils.


Kenneth Mosman

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.