

ASEC Report ID : 53176
Name of the Project : Estates at Old Friendship
Project Location : Buford, GA
Weather : 52
Departure Time : 02/07/2022
ASEC Technician Name : Russell Hendrix

Date : 02/24/2022
Project No : 2021C082
Client Company : CCG Constructors LLC (Century)
Arrival Time : 02/07/2022
Onsite Hours :

The site was visited by the undersigned AS Engineering and Consulting (ASEC) representative for the purpose of providing quality control inspection and testing services. Visual observation techniques were employed to assure compliance with project drawings/specifications, applicable codes, and materials submittals. The following observations were made on site today:

A site visit was conducted to determine the project conditions. It was determined that moisture content levels in the on-site surficial soils were too high for fill placement or compaction. The grading contractor crew were working on silt fence placement and preparing for rain.


Kenneth Mosman

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.