

ASEC Report ID : 34423
Name of the Project : Estates at Old Friendship
Project Location : Buford, GA
Weather : Partly Cloudy
Departure Time : 11/02/2021 12:00
ASEC Technician Name : Christopher Burrow II

Date : 11/02/2021
Project No : 2021C082
Client Company : CCG Constructors LLC (Century)
Arrival Time : 11/02/2021 09:00
Onsite Hours : 03:00

The undersigned ASEC Inspector was on site, on the above date, for the purpose of general site monitoring and assessment of contractor and subcontractor activities. The following are observations that were made at this time: The above-mentioned technician was present to observe groundwater discovered underneath roadway from a natural spring. The proposed and implemented solution was to place a French drain underneath the drainpipe placed in the area (area approximately 120' by 6') to drain the water out of the soil into the nearby creek.


Kenneth Mosman

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.