

ASEC Report ID : 54720
Name of the Project : Estates at Old Friendship
Project Location : Buford, GA
Weather : cloudy
Departure Time : 09/19/2022 12:00
ASEC Technician Name : Aminullah Azimi

Date : 09/19/2022
Project No : 2021C082
Client Company : CCG Constructors LLC (Century)
Arrival Time : 09/19/2022 9:00
Onsite Hours : 03:00

Our ASEC representative arrived on site, as requested, to observe:

The proof-roll of Friendship Falls Way from STA 0+00 to STA 17+00. The existing subgrade appeared to be at the finished grade elevation based on the information provided by grading contractor.

A fully loaded tandem axle dump truck was used to proof-roll the above the mentioned subgrade with multiple parallel and perpendicular passes across the area.

No severe pumping and/or deflection was observed during the proof-roll at the areas mentioned above.



Kenneth Mosman

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.