

ASEC Report ID : 54717
Name of the Project : Estates at Old Friendship
Project Location : Buford, GA
Weather : cloudy
Departure Time : 09/19/2022 12:00
ASEC Technician Name : Aminullah Azimi

Date : 09/19/2022
Project No : 2021C082
Client Company : CCG Constructors LLC (Century)
Arrival Time : 09/19/2022 9:00
Onsite Hours : 03:00

Our ASEC representative arrived on site, as requested, to observe:

Proof-rolling of the subgrade for Friendship Falls Way from STA 0+00 to STA 17+00. The existing subgrade appeared to be at finished grade elevation based on the information providing by the grading contractor,

A fully loaded tendon axle dump truck was used to proof-roll the above the mentioned subgrade with multiple parallel and perpendicular passes across the area.

No severe pumping and/or deflection were observed during the proof-roll at the above mentioned area.



Kenneth Mosman

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.