

ASEC Report ID : 54211
Name of the Project : Estates at Old Friendship
Project Location : Buford, GA
Weather :
Departure Time : 05/31/2022 11:00
ASEC Technician Name : Rasheen Biggins

Date : 05/31/2022
Project No : 2021C082
Client Company : CCG Constructors LLC (Century)
Arrival Time : 05/31/2022 07:30
Onsite Hours : 03:30

The site was visited by our AS Engineering and Consulting (ASEC) representative for the purpose of providing quality control inspection and testing services. Visual observation techniques were employed to assure compliance with project drawings/specifications, applicable codes, and materials submittals. The following observations were made on site today.

Upon arrival, our representative observed that work was in progress. The contractor requested footing inspections. Following visual and probing efforts and contacting our office, Mr. Ram Mogulla, P.E. of ASEC recommended that the contractor remove 6 inches of soft soils and replace with #57 stone. The contractor #57 stone in a 12ft x 17ft area along the wall footing.


Kenneth Mosman

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.