

Date : 02/20/2022
Project No : 2021C082
Client Company : CCG Constructors LLC (Century)
Arrival Time : 01/27/2022 10:00
Onsite Hours : 07:00

ASEC Report ID : 53119
Name of the Project : Estates at Old Friendship
Project Location : Buford, GA
Weather : 34 / sunny
Departure Time : 01/27/2022 17:00
ASEC Technician Name : Russell Hendrix

Test Date	Test Number	Moisture Content (%)	Dry Density (pcf)	Proctor Number	Max. Dry Density (pcf)	Optimum Moisture (%)	Compaction (%)	Specified Compaction (%)	ASTM Test Method	Pass/Fail
01/27/2022	1	15.9	102.5	P-1	109.6	15.7	93.5	95	D6938	Fail
Location : 14+00 main road @ detention pond, Elv/Depth :+1										
Comment :										
Tested By : Russell Hendrix Gauge Serial No. : 36089										
01/27/2022	2	15.2	93.1	P-1	109.6	15.7	84.9	95	D6938	Fail
Location : 14+00, Elv/Depth :+1										
Comment : This was a retest of same location.										
Tested By : Russell Hendrix Gauge Serial No. : 36089										
									D6938	Fail
Location : , Elv/Depth :										
Comment :										
Tested By : Russell Hendrix Gauge Serial No. :										

Remark: Test performed in general accordance with signed referenced ASTM Method.



Kenneth Mosman

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.

Date : 02/20/2022
Project No : 2021C082
Client Company : CCG Constructors LLC (Century)
Arrival Time : 01/27/2022 10:00
Onsite Hours : 07:00

ASEC Report ID : 53119
Name of the Project : Estates at Old Friendship
Project Location : Buford, GA
Weather : 34 / sunny
Departure Time : 01/27/2022 17:00
ASEC Technician Name : Russell Hendrix

PROCTOR DATA SUMMARY

TEST DATE	PROCTOR ID	MAX DRY DENSITY (pcf)	OPTIMUM MOISTURE (%)	PROCTOR TYPE	SOIL DESCRIPTION
10/20/2021	P-1	109.6	15.7	Standard	Light Brown Silty SAND
10/20/2021	P-2	102.2	20.3	Standard	Reddish Brown Silty SAND, with trace clay
10/20/2021	P-3	102.6	17.4	Standard	Light Brown Silty SAND
10/20/2021	P-4	104.2	19.3	Standard	Light Brown Silty SAND