

Date : 04/07/2023
Project No : 2022C106
Client Company : CWM
Arrival Time : 04/07/2023 11:30
Onsite Hours : 08:00

ASEC Report ID : 58457
Name of the Project : Taxiway 2022 Pavement Replacement
Project Location : HJAIA
Weather : cloudy
Departure Time : 04/07/2023 19:30
ASEC Technician Name : Aminullah Azimi

At the request of the client's representative, AS ENGINEERING AND CONSULTING, LLC (ASEC) representative, Amin Azimi visited the job site to observe and monitor the contractor's work activities from a quality standpoint to assure compliance with project drawings/specifications, applicable codes, and materials submittals and conducted QC testing per the project drawings and specifications. The following observations were made on site this shift:

- Work was being performed in the Lane 4 portion of the project on this day. Contractor completed rebar and dowel baskets for this lane.
- The writer verified proper installation and setup of this lane and advised the contractor representatives of any minor corrections that may be needed.
- The reinforcing steel was checked for correct size, number of bars, location of bars, spacing, cleanliness, support against displacement, splicing, clearance and steel grade. Based on visual observations and field measurements, the reinforcing steel at the above mentioned lane appeared to be acceptable.
- In addition to this, the writer assisted and observed straight edge testing of lane 1.

In case of any questions or concerns with regards to our observations or recommendations stated in this report we will be more than glad to discuss them with you.



Ramchandra R. Mogulla
GA P.E. 036021
Senior Engineer

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.