

Date : 04/17/2024
Project No : 2022C106
Client Company : CWM
Arrival Time : 04/17/2024 6:00
Onsite Hours : 12:00

ASEC Report ID : 66035
Name of the Project : Taxiway 2022 Pavement Replacement
Project Location : HJAIA
Weather : sunny
Departure Time : 04/17/2024 18:00
ASEC Technician Name : Aminullah Azimi

At the request of the client's representative, our AS ENGINEERING AND CONSULTING, LLC (ASEC) representative visited the job site to observe the contractor's work activities from a quality standpoint to verify compliance with project drawings/specifications, applicable codes, and materials submittals and conducted QC testing per the project drawings and specifications. The following observations were made on site this shift:

- A proof-roll observation was performed on the shoulder located in the east of Taxiway 22 phase 7B.
- A fully loaded water truck was used to proof-roll the above-mentioned subgrade with multiple passes across the area.
- No severe yielding and/or deflection was observed during the proof-roll at all areas mentioned above.
- Our representative along with Thomas of ATLQA and the ATLNext representative Braylyn observed the proof-roll.
- Installation of power lines for lights at western shoulder performed.
- ATL paving poured asphalt at eastern and western shoulder of phase 7A.
- Observed the placement and testing of concrete for west curb project at east roadway inside lane. from STA 107+40 to 108+90.
- Concrete observed on this date appeared to be placed in compliance with project specifications with regard to temperature, slump, air content, and batch to placement time.



Date : 04/17/2024
Project No : 2022C106
Client Company : CWM
Arrival Time : 04/17/2024 6:00
Onsite Hours : 12:00

ASEC Report ID : 66035
Name of the Project : Taxiway 2022 Pavement Replacement
Project Location : HJAIA
Weather : sunny
Departure Time : 04/17/2024 18:00
ASEC Technician Name : Aminullah Azimi



Kenneth Mosman

Kenneth Mosman

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.