

Date : 10/06/2023
Project No : 2022C165
Client Company : Toll Bros. Inc.
Arrival Time : 10/06/2023 07:00
Onsite Hours : 04:00

ASEC Report ID : 62281
Name of the Project : Northfield @ Polo Fields - Phase2
Project Location : Pittman Road, Cumming, GA
Weather : Cloudy
Departure Time : 10/06/2023 11:00
ASEC Technician Name : Vidal Dias

On October 6, 2023, Vidal Dias of AS ENGINEERING AND CONSULTING, LLC (ASEC) visited the site at the contractor's request to observe proofrolling of the remaining portions of Travers Lane, as illustrated in the attached drawing.

During the proof-rolling, conducted using a loaded dump truck, the entirety of the remaining sections of Travers Lane was thoroughly assessed. No significant rutting or deflection was observed throughout the examined span. The specific areas that underwent proof-rolling are highlighted and annotated in the drawing provided below.

The assessed sections of Travers Lane appear to be suitable for pavement placement, aligning with project plans and specifications.

AS Engineering and Consulting, LLC remains committed to ensuring the highest quality for this project. Should there be any questions or further clarifications needed regarding this report or any related documents, please don't hesitate to get in touch with us.



Vidal Dias

Project Geologist

Kenneth Mosman

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.