

Date : 10/09/2023
Project No : 2022C165
Client Company : Toll Bros. Inc.
Arrival Time : 10/09/2023 08:00
Onsite Hours : 02:00

ASEC Report ID : 62542
Name of the Project : Northfield @ Polo Fields - Phase2
Project Location : Pittman Road, Cumming, GA
Weather : Sunny
Departure Time : 10/09/2023 10:00
ASEC Technician Name : Vidal Dias

On October 9, 2023, Vidal Dias of AS ENGINEERING AND CONSULTING, LLC (ASEC) visited the site at the contractor's request to observe proof-rolling of the remaining portions of Asprey Lane, as illustrated in the attached drawing.

The proof-rolling was conducted using a loaded dump truck. During proof-roll activities, no significant rutting or deflection was observed throughout the examined span. The specific areas that underwent proof-rolling are highlighted and annotated in the drawing provided below.


The assessed sections appear to be suitable for pavement placement as per project plans and specifications.

Should there be any questions or further clarifications needed regarding this report or any related documents, please don't hesitate to get in touch with us.



Date : 10/09/2023
Project No : 2022C165
Client Company : Toll Bros. Inc.
Arrival Time : 10/09/2023 08:00
Onsite Hours : 02:00

ASEC Report ID : 62542
Name of the Project : Northfield @ Polo Fields - Phase2
Project Location : Pittman Road, Cumming, GA
Weather : Sunny
Departure Time : 10/09/2023 10:00
ASEC Technician Name : Vidal Dias



Vidal Dias

-
Project Geologist



Kenneth Mosman

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.