

Date : 02/09/2024  
Project No : 2022C165  
Client Company : Toll Bros. Inc.  
Arrival Time : 02/09/2024 14:00  
Onsite Hours : 02:00

ASEC Report ID : 64114  
Name of the Project : Northfield @ Polo Fields - Phase2  
Project Location : Pittman Road, Cumming, GA  
Weather : cloudy  
Departure Time : 02/09/2024 16:00  
ASEC Technician Name : Aminullah Azimi

| Test Date                                                          | Test Number | Moisture Content (%) | Dry Density (pcf) | Proctor Number | Max. Dry Density (pcf) | Optimum Moisture (%) | Compaction (%) | Specified Compaction (%) | ASTM Test Method | Pass/Fail |
|--------------------------------------------------------------------|-------------|----------------------|-------------------|----------------|------------------------|----------------------|----------------|--------------------------|------------------|-----------|
| 02/09/2024                                                         | 1           | 28.2                 | 86.0              | 1              | 83.2                   | 25.3                 | 103.4          | 95                       | D6938            | Pass      |
| Location : Lot #22, Elv/Depth :6 feet below finished grade         |             |                      |                   |                |                        |                      |                |                          |                  |           |
| Comment :                                                          |             |                      |                   |                |                        |                      |                |                          |                  |           |
| Tested By : Aminullah Azimi Gauge Serial No. : 85759               |             |                      |                   |                |                        |                      |                |                          |                  |           |
| 02/09/2024                                                         | 2           | 29.1                 | 86.1              | 1              | 83.2                   | 25.3                 | 103.5          | 95                       | D6938            | Pass      |
| Location : Lot #23, Elv/Depth :3 feet below finished grade         |             |                      |                   |                |                        |                      |                |                          |                  |           |
| Comment : Moisture content more than 3 percent higher than optimum |             |                      |                   |                |                        |                      |                |                          |                  |           |
| Tested By : Aminullah Azimi Gauge Serial No. : 85759               |             |                      |                   |                |                        |                      |                |                          |                  |           |

**Remark:** Test performed in general accordance with signed referenced ASTM Method.



**Kenneth Mosman**

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.

Date : 02/09/2024  
Project No : 2022C165  
Client Company : Toll Bros. Inc.  
Arrival Time : 02/09/2024 14:00  
Onsite Hours : 02:00

ASEC Report ID : 64114  
Name of the Project : Northfield @ Polo Fields - Phase2  
Project Location : Pittman Road, Cumming, GA  
Weather : cloudy  
Departure Time : 02/09/2024 16:00  
ASEC Technician Name : Aminullah Azimi

**PROCTOR DATA SUMMARY**

| TEST DATE  | PROCTOR ID | MAX DRY DENSITY (pcf) | OPTIMUM MOISTURE (%) | PROCTOR TYPE | SOIL DESCRIPTION                          |
|------------|------------|-----------------------|----------------------|--------------|-------------------------------------------|
| 10/25/2022 | 1          | 83.2                  | 25.3                 | Standard     | Reddish Brown Sandy CLAY                  |
| 10/25/2022 | 2          | 95.0                  | 23.5                 | Standard     | Tan Sandy CLAY                            |
| 10/25/2022 | 3          | 99.4                  | 21.3                 | Standard     | Reddish Brown Sandy CLAY                  |
| 03/21/2023 | 4          | 98.6                  | 20.2                 | Standard     | Reddish Brown Silty SAND w/ trace of Clay |
| 03/21/2023 | 5          | 93.8                  | 20.9                 | Standard     | Brown Sandy SILT w/ PWR Fragments         |