

Date : 05/18/2023
Project No : 2022C178
Client Company : CW Matthews
Arrival Time : 05/18/2023 13:00
Onsite Hours : 05:30

ASEC Report ID : 59364
Name of the Project : Ramp 2 Pavement Replacement
Project Location : HJAIA
Weather : cloudy
Departure Time : 05/18/2023 18:30
ASEC Technician Name : Aminullah Azimi

At the request of the client's representative, AS ENGINEERING AND CONSULTING, LLC (ASEC) representative, Amin Azimi visited the job site to observe and monitor the contractor's work activities from a quality standpoint to assure compliance with project drawings/specifications, applicable codes, and materials submittals and conducted QC testing per the project drawings and specifications. The following observations were made on site this shift:

- performed a proof-roll on subgrade soils that appeared to be at finished grade elevation based on provided information. A fully loaded tandem-axled dump truck was used to conduct the proof-roll of the above-mentioned subgrade with multiple passes across the area.

No severe yielding and/or deflection was observed during the proof-roll with the exception a small area, approximately (10×10) feet at location lane 1, panel 1 at the SE corner. It was recommended to undercut to a depth of 6" and replace with low slump concrete.

- Our representative along with Deion of 2Mnext and the Hazim ATLNext representative and CWM rep Brandon were present during all activities.
- Also observed straight edge activities in concourse D, lane TP 11.



Date : 05/18/2023
Project No : 2022C178
Client Company : CW Matthews
Arrival Time : 05/18/2023 13:00
Onsite Hours : 05:30

ASEC Report ID : 59364
Name of the Project : Ramp 2 Pavement Replacement
Project Location : HJAIA
Weather : cloudy
Departure Time : 05/18/2023 18:30
ASEC Technician Name : Aminullah Azimi



Kenneth Mosman

Kenneth Mosman

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.