

Date : 10/19/2023
Project No : 2022C207
Client Company : Techcon
Arrival Time : 10/19/2023 10:00
Onsite Hours : 04:00

ASEC Report ID : 62701
Name of the Project : CME Church Education Center
Project Location : College Park
Weather : sunny
Departure Time : 10/19/2023 14:00
ASEC Technician Name : Aminullah Azimi

Test Date	Test Number	Moisture Content (%)	Dry Density (pcf)	Proctor Number	Max. Dry Density (pcf)	Optimum Moisture (%)	Compaction (%)	Specified Compaction (%)	ASTM Test Method	Pass/Fail
10/19/2023	1	7.7	114.0				Infinity		D6938	Pass
Location : 10 feet away from Southwest corner, Elv/Depth :finish grade										
Comment : we need proctor for result										
Tested By : Aminullah Azimi Gauge Serial No. : 85759										
10/19/2023	2	7.2	115.2				Infinity		D6938	Pass
Location : in meddle of lot , Elv/Depth :finish grade										
Comment : Need proctor for result										
Tested By : Aminullah Azimi Gauge Serial No. : 85759										
10/19/2023	3	7.7	118.8				Infinity		D6938	Pass
Location : 20 feet away from Northeast corner, Elv/Depth :finish grade										
Comment : Need proctor for result										
Tested By : Aminullah Azimi Gauge Serial No. : 85759										

Remark: Test performed in general accordance with signatured referenced ASTM Method.



Ramchandra R. Mogulla
GA P.E. 036021
Senior Engineer

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.

Date : 10/19/2023
Project No : 2022C207
Client Company : Techcon
Arrival Time : 10/19/2023 10:00
Onsite Hours : 04:00

ASEC Report ID : 62701
Name of the Project : CME Church Education Center
Project Location : College Park
Weather : sunny
Departure Time : 10/19/2023 14:00
ASEC Technician Name : Aminullah Azimi

PROCTOR DATA SUMMARY

TEST DATE	PROCTOR ID	MAX DRY DENSITY (pcf)	OPTIMUM MOISTURE (%)	PROCTOR TYPE	SOIL DESCRIPTION
-----------	------------	--------------------------	----------------------	--------------	------------------