

Date : 09/20/2023
Project No : 2022C227
Client Company : Artisan
Arrival Time : 09/20/2023 09:00
Onsite Hours : 07:45

ASEC Report ID : 62451
Name of the Project : Riverwalk Manor (CMT) Unit 2, PH 4E
and 4F
Project Location : Dallas
Weather : Clear skies
Departure Time : 09/20/2023 16:45
ASEC Technician Name :

The above-mentioned AS Engineering and Consulting (ASEC) representative, visited the River Walk Manor site to conduct quality control inspection and testing services. Visual observation techniques were employed to verify compliance with project drawing/specifications, applicable codes, and materials submittals.

The following observations were made on-site:

- Rock Volume Determination for the blast performed on this date: Rock volume was determined based on the attached drill logs. Drilling was performed on the days leading to today and depths to top of rock and termination was recorded.
- The total quantity of mass rock shot on this day was calculated to be 2,742.2 cubic yards.

We appreciate the opportunity to be of service to you on this project. If you have any questions regarding this report, please feel free to contact us. We will be more than happy to discuss it with you.



Ramchandra R. Mogulla
GA P.E. 036021
Senior Engineer

Kenneth Mosman

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.