

Date : 02/06/2023
Project No : 2022C235
Client Company : Jackson Demolition Service, Inc.
Arrival Time : 02/06/2023 06:00
Onsite Hours : 10:30

ASEC Report ID : 56563
Name of the Project : Plant Gorgas Demolition and Grading
Project Location : 460 Gorgas Rd, Parrish, AL 35580
Weather : Sunny
Departure Time : 02/06/2023 16:30
ASEC Technician Name : Vidal Dias

AS ENGINEERING AND CONSULTING, LLC (ASEC) representative Vidal Dias visited the site at the request of Jackson Demolition representative Josh Kelly. The undersigned representative was present to monitor, verify and document the ongoing project activities.

During the visit, the following observations were made:

1. The contractor installed stakes over the previously prepared Geogrid layer in unit 10 areas G7 and G8 and attached a ribbon to each stake to mark approximate elevations for placing the 825B aggregate.
2. As shown in the attached images, the green ribbon is the top elevation for the 825B GAB.
3. Each stake was measured at least 12" from the subgrade, which meets the specifications noted on drawing E720667.

Photo documentation is included below:



Ramchandra Mogulla, PE
31220
Senior Engineer

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.