

Date : 11/06/2023
Project No : 2023C111
Client Company : 2MATL
Arrival Time : 11/06/2023 11:00
Onsite Hours : 03:00

ASEC Report ID : 62906
Name of the Project : DOA Fiber Infrastructure Improvements
Project Location : HJAIA
Weather : sunny
Departure Time : 11/06/2023 14:00
ASEC Technician Name : Aminullah Azimi

Test Date	Test Number	Moisture Content (%)	Dry Density (pcf)	Proctor Number	Max. Dry Density (pcf)	Optimum Moisture (%)	Compaction (%)	Specified Compaction (%)	ASTM Test Method	Pass/Fail
11/06/2023	1	20.6	99.6				Infinity		D6938	Pass
Location : 31 feet to West of MHA2, Elv/Depth :3 feet below finish grade										
Comment : Need proctor for result.										
Tested By : Aminullah Azimi Gauge Serial No. : 85759										
11/06/2023	2	19.4	100.1				Infinity		D6938	Pass
Location : 40 feet to West of MHA2, Elv/Depth :2.5 feet below finish grade										
Comment : Need proctor for result.										
Tested By : Aminullah Azimi Gauge Serial No. : 85759										
									D6938	Fail
Location : , Elv/Depth :										
Comment :										
Tested By : Aminullah Azimi Gauge Serial No. :										

Remark: Test performed in general accordance with signed referenced ASTM Method.



Kenneth Mosman

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.

Date : 11/06/2023
Project No : 2023C111
Client Company : 2MATL
Arrival Time : 11/06/2023 11:00
Onsite Hours : 03:00

ASEC Report ID : 62906
Name of the Project : DOA Fiber Infrastructure Improvements
Project Location : HJAIA
Weather : sunny
Departure Time : 11/06/2023 14:00
ASEC Technician Name : Aminullah Azimi

PROCTOR DATA SUMMARY

TEST DATE	PROCTOR ID	MAX DRY DENSITY (pcf)	OPTIMUM MOISTURE (%)	PROCTOR TYPE	SOIL DESCRIPTION
03/04/2023	M10	119.0	11.4	Modified	M10 Sand