

Date : 10/23/2023  
Project No : 2023C136  
Client Company : Excellere  
Arrival Time : 10/23/2023 13:00  
Onsite Hours : 02:00

ASEC Report ID : 62662  
Name of the Project : Big Creek Boardwalks  
Project Location : Alpharetta  
Weather : Clear skies  
Departure Time : 10/23/2023 15:00  
ASEC Technician Name : Ramchandra Mogulla

---

AS ENGINEERING AND CONSULTING, LLC (ASEC) representative Vidal Dias visited the site at the request of Excellere Construction representative Martha Herrera. The undersigned representative was present to visually inspect bolted connections that were installed along the Mansell Spur section of the project between Bent 8 and Bent 4.

During the visit, the following observations were made:

**Bolted Connections:**

- Inspected bolted connections at the designated locations for adherence to specific criteria, including bolt placement, and complete nut engagement.
- Verified that the bolted connections within the area inspected as mentioned above appeared to be acceptable and are in general accordance with the relevant AISC/RCSC code requirements as well as the project specifications for snug-tight conditions.

**Beam-Column Moment Connection Inspection:**

- Examined bolted beam-to-column moment connections within the inspection area as mentioned above.
- Verified the fastener assemblies within these bolted beam connections to ensure alignment with contract requirements pertaining to size, components, assembly order, and orientation.
- Confirmed that the fastener assemblies exhibit a snug-tight condition consistent with the project drawings.

Conclusion: The site visit conducted on October 23, 2023, provided an assessment of ongoing project activities for the Big Creek Boardwalk. The observations made during the visit attest to the compliance of bolted connections for snug-tight conditions with relevant industry standards.

If you have any questions or require further clarification regarding the content of this report, please do not hesitate to get in touch. We are readily available to address any inquiries you may have.

Date : 10/23/2023  
Project No : 2023C136  
Client Company : Excellere  
Arrival Time : 10/23/2023 13:00  
Onsite Hours : 02:00

ASEC Report ID : 62662  
Name of the Project : Big Creek Boardwalks  
Project Location : Alpharetta  
Weather : Clear skies  
Departure Time : 10/23/2023 15:00  
ASEC Technician Name : Ramchandra Mogulla



Bent 4



Date : 10/23/2023  
Project No : 2023C136  
Client Company : Excellere  
Arrival Time : 10/23/2023 13:00  
Onsite Hours : 02:00

ASEC Report ID : 62662  
Name of the Project : Big Creek Boardwalks  
Project Location : Alpharetta  
Weather : Clear skies  
Departure Time : 10/23/2023 15:00  
ASEC Technician Name : Ramchandra Mogulla



**Ramchandra R. Mogulla**  
GA P.E. 036021  
Senior Engineer

*Kenneth Mosman*

**Kenneth Mosman**

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.