

Date : 12/05/2023
Project No : 2023C141
Client Company : Toll Bros
Arrival Time : 12/05/2023 9:30
Onsite Hours : 03:00

ASEC Report ID : 63222
Name of the Project : N. Gate - Old Atlanta Road
Project Location : Cumming
Weather : sunny
Departure Time : 12/05/2023 12:30
ASEC Technician Name : Aminullah Azimi

At the request of the client's representative, our AS ENGINEERING AND CONSULTING, LLC (ASEC) representative visited the job site to observe the contractor's work activities from a quality standpoint to verify compliance with project drawings/specifications, applicable codes, and materials submittals and conducted QC testing per the project drawings and specifications. The following observations were made on site this shift:

- A proof-roll observation was performed on the ditch location (highlighted by yellow in sketch); at the time of arrival contractor already compacted 5 feet, (to 7 feet from finished grade).
- A fully loaded tandem-axle dump truck was used to proof-roll the above-mentioned location with multiple passes across the area.
- No severe yielding and/or deflection was observed during the proof-roll at all areas mentioned above.



ASEC Report ID : 63222
Name of the Project : N. Gate - Old Atlanta Road
Project Location : Cumming
Weather : sunny
Departure Time : 12/05/2023 12:30
ASEC Technician Name : Aminullah Azimi

Date : 12/05/2023
Project No : 2023C141
Client Company : Toll Bros
Arrival Time : 12/05/2023 9:30
Onsite Hours : 03:00



Kenneth Mosman

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.