

Date : 02/09/2024
Project No : 2023C141
Client Company : Toll Bros
Arrival Time : 02/09/2024 10:00
Onsite Hours : 04:00

ASEC Report ID : 64102
Name of the Project : N. Gate - Old Atlanta Road
Project Location : Cumming
Weather : cloudy
Departure Time : 02/09/2024 14:
ASEC Technician Name : Aminullah Azimi

As requested, the site was visited by our AS Engineering and Consulting (ASEC) representative for the purpose of providing quality control inspection and testing services. Visual observation techniques were employed to verify compliance with project drawing/specifications, applicable codes, and materials submittals. The following observations were observed on site this day.

- The placement and compaction of backfill soils for the sewer pipe trench between Manholes A4 to A5 and A6 and lot 25 and fill soils for Lot #32 and the roadway in front of Lot #25, continued this day.
- At the time of arrival, our representative observed that work was in progress with 1-foot lifts being placed and compacted using a 12-ton sheeps-foot compactor.
- Density test results indicate that the compacted materials met the project requirement of 90% of the maximum dry density obtained by the (Standard Proctor ASTM 698),

We appreciate the opportunity to be of service to you on this project. If you have any questions regarding this report, please feel free to contact us. We will be more than happy to discuss it with you.



Date : 02/09/2024
Project No : 2023C141
Client Company : Toll Bros
Arrival Time : 02/09/2024 10:00
Onsite Hours : 04:00

ASEC Report ID : 64102
Name of the Project : N. Gate - Old Atlanta Road
Project Location : Cumming
Weather : cloudy
Departure Time : 02/09/2024 14:
ASEC Technician Name : Aminullah Azimi





AS Engineering
and Consulting LLC

Daily Field Report

ASEC Report ID : 64102
Name of the Project : N. Gate - Old Atlanta Road
Project Location : Cumming
Weather : cloudy
Departure Time : 02/09/2024 14:
ASEC Technician Name : Aminullah Azimi

Date : 02/09/2024
Project No : 2023C141
Client Company : Toll Bros
Arrival Time : 02/09/2024 10:00
Onsite Hours : 04:00

Kenneth Mosman

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.