



Date : 04/13/2024
Project No : 2023C159
Client Company : CW Matthews
Arrival Time : 04/13/2024 14:00
Onsite Hours : 04:00

ASEC Report ID : 66002
Name of the Project : Airfield Repairs 2021-23
Project Location : HJAlA, Atlanta, GA
Weather : cloudy
Departure Time : 04/13/2024 18:00
ASEC Technician Name : Aminullah Azimi

As requested, the site was visited by our AS Engineering and Consulting (ASEC) representative for the purpose of providing quality control inspection and testing services. Visual observation techniques were employed to verify compliance with project drawing/specifications, applicable codes, and materials submittals. The following observations were observed on site this day.


- The placement and compaction of asphalt surface course for Airfield north shoulder between B3 and B5 of runway 5, lane 1 and 2, continued this day.
- At the time of arrival, our representative observed that work was in progress with 12 mm lifts being placed.
- Test results indicate that the compacted materials met the project requirement of 95% of the maximum wet density obtained by the laboratory.
- Test#1, location, lane 1, 120 feet to west from east end, with wet density = 144.8 pcf.
- Test#2, location, lane 1, 330 feet to west from east end, with wet density = 148.0 pcf.
- Test#3, location, lane 1, 430 feet to west from east end, with wet density = 148.1 pcf.
- Test#4, location, lane2, 120 feet to west from east end, with wet density = 147.6 pcf.
- Test#5, location, lane2, 330 feet to west from east end, with wet density = 145.9 pcf.

We appreciate the opportunity to be of service to you on this project. If you have any questions regarding this report, please feel free to contact us. We will be more than happy to discuss it with you.



Date : 04/13/2024
Project No : 2023C159
Client Company : CW Matthews
Arrival Time : 04/13/2024 14:00
Onsite Hours : 04:00

ASEC Report ID : 66002
Name of the Project : Airfield Repairs 2021-23
Project Location : HJAJA, Atlanta, GA
Weather : cloudy
Departure Time : 04/13/2024 18:00
ASEC Technician Name : Aminullah Azimi



Kenneth Mosman

Kenneth Mosman

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.