

Date : 06/30/2024
Project No : 2023C161
Client Company : Pulte
Arrival Time : 06/30/2024 9:00
Onsite Hours : 03:00

ASEC Report ID : 66803
Name of the Project : Addison Grove - AC Smith Rd
Project Location : Cumming / Dawsonville
Weather : sunny
Departure Time : 06/30/2024 12:00
ASEC Technician Name : Aminullah Azimi

At the request of the client's representative, AS ENGINEERING AND CONSULTING, LLC (ASEC) representative, Amin Azimi visited the job site to visually observe the contractor's work activities from a quality standpoint to verify compliance with project drawings/specifications, applicable codes, and materials submittals and conducted QC testing per the project drawings and specifications. The following observations were made on site this shift:

- Observed the placement of reinforcement for basement walls, Lot #36 this day.
- The reinforcing steel was checked for correct size, number of bars, location of bars, spacing, cleanliness, support against displacement, splicing, clearance and steel grade. Based on visual observations and field measurements, the reinforcing steel at the above-mentioned lane appeared to meet job specifications for size, spacing and quantity.
- Based on observation and field measuring, the reinforcing steel at the above-mentioned basement walls appeared to be placed according to shop/field-use drawings for size, spacing and quantity.

In case of any questions or concerns with regards to our observations or recommendations stated in this report we will be more than glad to discuss them with you.



Date : 06/30/2024
Project No : 2023C161
Client Company : Pulte
Arrival Time : 06/30/2024 9:00
Onsite Hours : 03:00

ASEC Report ID : 66803
Name of the Project : Addison Grove - AC Smith Rd
Project Location : Cumming / Dawsonville
Weather : sunny
Departure Time : 06/30/2024 12:00
ASEC Technician Name : Aminullah Azimi



Kenneth Mosman

Kenneth Mosman

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.