

Date : 10/30/2023
Project No : 2023C195
Client Company : Toll Bros. Inc.
Arrival Time : 10/30/2023 08:00
Onsite Hours : 04:00

ASEC Report ID : 62816
Name of the Project : Kimbal Bridge Tract
Project Location : Alpharetta
Weather : suuny
Departure Time : 10/30/2023 12:00
ASEC Technician Name : Vidal Dias

Our ASEC representative visited the site upon request by the contractor to observe the proof-rolling operations for the proposed roadway adjacent to Lots #15 - 21, near the beginning of the wetland boundary. A CAT 740B articulated dump truck loaded with soil was employed to conduct the proof-roll.

During the proof-roll, conducted across the designated area, it was observed that:



- The soil subgrade under the loaded dump truck showed no signs of severe deflection or rutting.
- The subgrade soils appear suitable for continued backfilling.

The subgrade displayed the necessary structural integrity and stability, indicating that the current conditions are conducive for the contractor to continue with backfilling operations.



Date : 10/30/2023
Project No : 2023C195
Client Company : Toll Bros. Inc.
Arrival Time : 10/30/2023 08:00
Onsite Hours : 04:00

ASEC Report ID : 62816
Name of the Project : Kimbal Bridge Tract
Project Location : Alpharetta
Weather : sunny
Departure Time : 10/30/2023 12:00
ASEC Technician Name : Vidal Dias



Vidal Dias

-
Project Geologist



Kenneth Mosman

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.