

Date : 01/24/2024
Project No : 2023C195
Client Company : Toll Bros. Inc.
Arrival Time : 01/24/2024 11:00
Onsite Hours : 05:00

ASEC Report ID : 63826
Name of the Project : Kimbal Bridge Tract
Project Location : Alpharetta
Weather : Cloudy
Departure Time : 01/24/2024 16:00
ASEC Technician Name : Aminullah Azimi

As requested, the site was visited by our AS Engineering and Consulting (ASEC) representative for the purpose of providing quality control inspection and testing services. Visual observation techniques were employed to verify compliance with project drawing/specifications, applicable codes, and materials submittals. The following observations were observed on site this day:

Observed the final reinforcement placement for retaining wall footing (location shown in picture).

The reinforcing steel was observed for correct size, number of bars, location of bars, spacing, cleanliness, support against displacement, splicing, clearance and steel grade.

Observed the placement and testing of 72 cubic yards of 3000 psi concrete for footing of retaining wall 9.



Kenneth Mosman

Kenneth Mosman

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.