

Date : 02/07/2024
Project No : 2023C195
Client Company : Toll Bros. Inc.
Arrival Time : 02/07/2024 8:30
Onsite Hours : 07:00

ASEC Report ID : 64034
Name of the Project : Kimbal Bridge Tract
Project Location : Alpharetta
Weather : sunny
Departure Time : 02/07/2024 15:30
ASEC Technician Name : Aminullah Azimi

As requested, the site was visited by our AS Engineering and Consulting (ASEC) representative for the purpose of providing quality control inspection and testing services. Visual observation techniques were employed to verify compliance with project drawing/specifications, applicable codes, and materials submittals. The following observations were observed on site this day.

As requested, observed the reinforcing steel for retaining wall 9 prior to concrete placement.

The reinforcing steel was observed for correct size, number of bars, location of bars, spacing, cleanliness, support against displacement, splicing, clearance and steel grade. Based on observation and field measuring, the reinforcing steel at the above mentioned:

- wall reinforcement appeared to be placed according to Shop/field drawing 1A of 3 for size, spacing and quantity.

Observed the placement of 81 cubic yards of 3000 psi concrete for retaining wall 9.

We appreciate the opportunity to be of service to you on this project. If you have any questions regarding this report, please feel free to contact us. We will be more than happy to discuss it with you.



Kenneth Mosman

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.