

Date : 03/20/2024
Project No : 2023C206
Client Company : CWM-JVTECH
Arrival Time : 03/20/2024 7:30
Onsite Hours : 04:30

ASEC Report ID : 65401
Name of the Project : Concourse D Widening
Project Location : HJAIA
Weather : sunny
Departure Time : 03/20/2024 12:00
ASEC Technician Name : Aminullah Azimi

At the request of the client's representative, our AS ENGINEERING AND CONSULTING, LLC (ASEC) representative, Amin Azimi visited the job site to observe the contractor's work activities from a quality standpoint to verify compliance with project drawings/specifications, applicable codes, and materials submittals and conducted QC testing per the project drawings and specifications. The following observations were made on site this shift:

Observed the placement of LS concrete for Concourse D, location (Shown LS1 in sketch) located to the south of MH1,

The required test limits were determined to be a slump of 1/2" to 2.1/2", air content of 3-8 %, batch to placement time of 0-90 minutes, and concrete temperature range of 55-90 degrees Fahrenheit.

Concrete observed on this date appeared to be placed in compliance with project specifications with regard to temperature, air content, and batch to placement time.

In case of any questions or concerns with regards to our observations or recommendations stated in this report we will be more than glad to discuss them with you.



Kenneth Mosman

Kenneth Mosman

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.