

Date : 05/30/2024
Project No : 2024C116
Client Company : Peeples Owner, LLC
Arrival Time : 05/30/2024 08:15
Onsite Hours : 9:15

ASEC Report ID : 66777
Name of the Project : Peeples Valley Rd, Overlook at Pettit
Project Location : Cartersville
Weather : Sunny
Departure Time : 05/30/2024 17:30
ASEC Technician Name : Fawad Shagiwal

As requested, the site was visited by our AS Engineering and Consulting (ASEC) representative for the purpose of providing quality control inspection and testing services.

The following observations were observed on site this day:

- The placement and compaction of backfill soils for an 8115.8 square-foot area was in progress using a sheeps-foot (CP54B), (RA30), (D51PX) and (CAT330) rollers.
- At the time of arrival our representative observed that work was in progress with 12-inch lifts being placed and compacted using a sheeps-foot (CP54B) and (D51PX) equipment.
- Density tests results indicate that the compacted material met the project requirements of 95% of the maximum dry density obtained by a standard proctor ASTM 698.



Date : 05/30/2024
Project No : 2024C116
Client Company : Peeples Owner, LLC
Arrival Time : 05/30/2024 08:15
Onsite Hours : 9:15

ASEC Report ID : 66777
Name of the Project : Peeples Valley Rd, Overlook at Pettit
Project Location : Cartersville
Weather : Sunny
Departure Time : 05/30/2024 17:30
ASEC Technician Name : Fawad Shagiwal



Kenneth Mosman

Kenneth Mosman

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.