

Date : 07/18/2024
Project No : 2024C116
Client Company : Peeples Owner, LLC
Arrival Time : 07/18/2024 08:00
Onsite Hours : 08:30

ASEC Report ID : 67947
Name of the Project : Peeples Valley Rd, Overlook at Pettit
Project Location : Cartersville
Weather : Cloudy
Departure Time : 07/18/2024 16:30
ASEC Technician Name : Fawad Shagiwal

As requested the site was visited by our AS Engineering and Consulting (ASEC) representative for the purpose of providing quality control inspection and testing services. Visual observation techniques were employed to verify compliance with project drawings/specifications, applicable codes and material submittals.

The following observations were observed on the site this day.

- The placement and compaction of backfill soil of lots # 84 to 93 was in progressed using sheep foot (CP54B), (RA30), (D51PX) and (CAT330) equipments.
- Excavation and preparation of foundation for placement and construction of box Culverts at out let area of storm water pound was in progressed.
- Excavation and preparation of foundation for construction of segmental retaining wall section #D was in progressed.
- Installation and placement of CIB2 4'0 1/2 storm water main holes and pipes was completed.
- At the time of arrival our representative observed that the work was in progress in lots #84 to 93 and 01 foot lift being placed and compacted using sheep foot (CP54B) and (D51PX) equipments as well.
- Density test results indicate that the compacted material met the project requirements of 95% the maximum dry density obtained by the (Standard Proctor ASTM 698).



Date : 07/18/2024
Project No : 2024C116
Client Company : Peeples Owner, LLC
Arrival Time : 07/18/2024 08:00
Onsite Hours : 08:30

ASEC Report ID : 67947
Name of the Project : Peeples Valley Rd, Overlook at Pettit
Project Location : Cartersville
Weather : Cloudy
Departure Time : 07/18/2024 16:30
ASEC Technician Name : Fawad Shagiwal



Date : 07/18/2024
Project No : 2024C116
Client Company : Peeples Owner, LLC
Arrival Time : 07/18/2024 08:00
Onsite Hours : 08:30

ASEC Report ID : 67947
Name of the Project : Peeples Valley Rd, Overlook at Pettit
Project Location : Cartersville
Weather : Cloudy
Departure Time : 07/18/2024 16:30
ASEC Technician Name : Fawad Shagiwal



The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.