

Date : 08/19/2024
Project No : 2024C116
Client Company : Peeples Owner, LLC
Arrival Time : 08/19/2024 08:45
Onsite Hours : 08:15

ASEC Report ID : 68948
Name of the Project : Peeples Valley Rd, Overlook at Pettit
Project Location : Cartersville
Weather : Sunny
Departure Time : 08/19/2024 17:00
ASEC Technician Name : Fawad Shagiwal

As requested the site was visited by our AS Engineering and Consulting (ASEC) representative for the purpose of providing quality control inspection and testing services. Visual observation techniques were employed to verify compliance with project drawings/specifications, applicable codes and material submittals.

The following observations were observed on the site this day.

- Construction and placement of Sta 4+18, a 50-foot-long segmental retaining wall (SRW) section #B was completed.
- A soft and wet section of roadway along the north side of the permanent storm water pond by dimensions of (L=200 feet, Width=35 feet, Depth=4 feet), was found to require scarification, aeration and recompaction.
- Excavation and preparation of trench for placement and installation of sewer lines and manholes progressed.
- Excavation and preparation of trench for placement and installation of storm water lines and manholes progressed.
- Installation and placement of sewer lines and MH SSD4 continued.
- Installation and placement of storm water MH CIA4 progressed.





Date : 08/19/2024
Project No : 2024C116
Client Company : Peeples Owner, LLC
Arrival Time : 08/19/2024 08:45
Onsite Hours : 08:15

ASEC Report ID : 68948
Name of the Project : Peeples Valley Rd, Overlook at Pettit
Project Location : Cartersville
Weather : Sunny
Departure Time : 08/19/2024 17:00
ASEC Technician Name : Fawad Shagiwal



Date : 08/19/2024
Project No : 2024C116
Client Company : Peeples Owner, LLC
Arrival Time : 08/19/2024 08:45
Onsite Hours : 08:15

ASEC Report ID : 68948
Name of the Project : Peeples Valley Rd, Overlook at Pettit
Project Location : Cartersville
Weather : Sunny
Departure Time : 08/19/2024 17:00
ASEC Technician Name : Fawad Shagiwal



Kenneth Mosman

Kenneth Mosman

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.