

Date : 08/21/2024
 Project No : 2024C168
 Client Company : CCG
 Arrival Time : 08/21/2024 9:45
 Onsite Hours : 08:45

ASEC Report ID : 69072
 Name of the Project : Reserve @ Gum Springs
 Project Location : Jefferson
 Weather : sunny
 Departure Time : 08/21/2024 18:30
 ASEC Technician Name : Aminullah Azimi

Test Date	Test Number	Moisture Content (%)	Dry Density (pcf)	Proctor Number	Max. Dry Density (pcf)	Optimum Moisture (%)	Compaction (%)	Specified Compaction (%)	ASTM Test Method	Pass/Fail
08/21/2024	1	25.1	87.5	26085	92.0	25.3	95.1	95	D6938	Pass
Location : Lot #243, Elv/Depth :1 foot below finished grade										
Comment :										
Tested By : Aminullah Azimi Gauge Serial No. : 85759										
08/21/2024	2	26.4	89.6	26082	94.1	24.3	95.2	95	D6938	Pass
Location : Lot #242, Elv/Depth :1 foot below finished grade										
Comment :										
Tested By : Aminullah Azimi Gauge Serial No. : 8579										
08/21/2024	3	26	88.3	26085	92.0	25.3	96.0	95	D6938	Pass
Location : Lot #241, Elv/Depth :1 foot below finished grade										
Comment :										
Tested By : Aminullah Azimi Gauge Serial No. : 85759										
08/21/2024	4	26.1	90.3	26082	94.1	24.3	96.0	95	D6938	Pass
Location : Lot #240, Elv/Depth :2 feet below finished grade										
Comment :										
Tested By : Aminullah Azimi Gauge Serial No. : 85759										
08/21/2024	5	25.9	90.3	26082	94.1	24.3	96.0	95	D6938	Pass
Location : Lot #239, Elv/Depth :113.7										
Comment :										
Tested By : Aminullah Azimi Gauge Serial No. : 85759										
08/21/2024	6	26.1	112.8	26082	94.1	24.3	95.1	95	D6938	Pass
Location : Sewer trench, 34 feet south of MH A11, Elv/Depth :2 feet below finished grade										
Comment :										
Tested By : Aminullah Azimi Gauge Serial No. : 85759										
08/21/2024	7	25.7	90.3	26082	94.1	24.3	96.0	95	D6938	Pass
Location : Sewer trench, 108 feet south of MH A11, Elv/Depth :1.5 feet below finished grade										
Comment :										
Tested By : Aminullah Azimi Gauge Serial No. : 85759										
08/21/2024	8	25.2	109.5	26085	92.0	25.3	95.1	95	D6938	Pass
Location : Lot #149, Elv/Depth :1 foot below finished grade										
Comment :										
Tested By : Aminullah Azimi Gauge Serial No. : 85759										
08/21/2024	9	24.5	108.9	26085	92.0	25.3	95.1	95	D6938	Pass
Location : Lot #148, Elv/Depth :1 foot below finished grade										
Comment :										
Tested By : Aminullah Azimi Gauge Serial No. : 85759										
08/21/2024	10	24.2	89.6	26082	94.1	24.3	95.2	95	D6938	Pass
Location : Lot #147, Elv/Depth :3.5 feet below finished grade										
Comment :										
Tested By : Aminullah Azimi Gauge Serial No. : 85759										
08/21/2024	12	24.0	89.5	26082	94.1	24.3	95.1	95	D6938	Pass
Location : Lot #145, Elv/Depth :4.5 feet below finished grade										

Density Test Report

Date : 08/21/2024
Project No : 2024C168
Client Company : CCG
Arrival Time : 08/21/2024 9:45
Onsite Hours : 08:45

ASEC Report ID : 69072
Name of the Project : Reserve @ Gum Springs
Project Location : Jefferson
Weather : sunny
Departure Time : 08/21/2024 18:30
ASEC Technician Name : Aminullah Azimi

Test Date	Test Number	Moisture Content (%)	Dry Density (pcf)	Proctor Number	Max. Dry Density (pcf)	Optimum Moisture (%)	Compaction (%)	Specified Compaction (%)	ASTM Test Method	Pass/Fail
Comment :										
Tested By :		Aminullah Azimi				Gauge Serial No. : 85759				
08/21/2024	13	26	90.3	26082	94.1	24.3	96.0	95	D6938	Pass
Location : Lot #13, Elv/Depth :4.5 feet below finished grade										
Comment :										
Tested By :		Aminullah Azimi				Gauge Serial No. : 85759				

Remark: Test performed in general accordance with signed referenced ASTM Method.


Kenneth Mosman

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.

Date : 08/21/2024
Project No : 2024C168
Client Company : CCG
Arrival Time : 08/21/2024 9:45
Onsite Hours : 08:45

ASEC Report ID : 69072
Name of the Project : Reserve @ Gum Springs
Project Location : Jefferson
Weather : sunny
Departure Time : 08/21/2024 18:30
ASEC Technician Name : Aminullah Azimi

PROCTOR DATA SUMMARY

TEST DATE	PROCTOR ID	MAX DRY DENSITY (pcf)	OPTIMUM MOISTURE (%)	PROCTOR TYPE	SOIL DESCRIPTION
07/01/2024	26081	102.9	20.0	Standard	Reddish Brown Sandy SILT
07/01/2024	26082	94.1	24.3	Standard	Brown Sandy SILT
07/01/2024	26083	102.0	22.1	Standard	Light Brown Sandy SILT
07/26/2024	26084	102.0	19.6	Standard	Brown Sandy SILT
07/26/2024	26085	92.0	25.3	Standard	Reddish-Brown Sandy SILT