

Date : 08/22/2024
Project No : 2024C195
Client Company : CWM
Arrival Time : 08/21/2024 18:00
Onsite Hours : 07:45

ASEC Report ID : 69027
Name of the Project : Ramp 21 Replacement
Project Location : HJAIA
Weather : Clear sky
Departure Time : 08/22/2024 01:45
ASEC Technician Name : Solomon Cherie

As requested, our AS Engineering & Consulting LLC representative was on site to observe site activities. The following were performed this day:

- 1) Moisture tests were taken.
 - 2) Stripped one set of seven beams and one set of four cylinders from yesterday's pour.
 - 3) Air content tests, concrete temperature, slump and unit weight were taken for the first truck sampled.
 - 4) Two sets of beams were cast, one each from Truck #20 and #61. Seven beams cast for each truck.
- All concrete tests were found to be within job specifications.



Kenneth Mosman

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.