

Date : 08/24/2024
Project No : 2024C195
Client Company : CWM
Arrival Time : 08/24/2024 16:00
Onsite Hours : 9:15

ASEC Report ID : 69085
Name of the Project : Ramp 21 Replacement
Project Location : HJAIA
Weather : Clear sky
Departure Time : 08/25/2024 01:15
ASEC Technician Name : Solomon Cherie

As requested, our AS Engineering & Consulting LLC representative was on site to observe concrete placement. The following were performed this day:

- 1) Moisture tests were taken (for rock and sand materials).
 - 2) Air content tests, concrete temperature, slump and unit weight were taken for Truck #1 sampled.
 - 3) One set of eleven (11) beams were cast.
 - 4) Stripped two sets of eleven (11) beams and placed in curing.
- All concrete tests were found to be within job specifications.

Note: one set of beams was also cast for Taxiway 2022.



Kenneth Mosman

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.