

Date : 08/28/2024
Project No : 2024C195
Client Company : CWM
Arrival Time : 08/28/2024 05:00
Onsite Hours : 03:00

ASEC Report ID : 69244
Name of the Project : Ramp 21 Replacement
Project Location : HJAIA
Weather : Clear sky
Departure Time : 08/28/2024 08:00
ASEC Technician Name : Solomon Cherie

As requested, our AS Engineering & Consulting LLC representative was on site to observe concrete placement. The following were performed this day:

- 1) Cast one four (4) sets of four (4) 6" x 12" cylinders for low slump/low energy concrete.



Kenneth Mosman

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.