

Date : 10/04/2024
Project No : 2024C195
Client Company : CWM
Arrival Time : 10/04/2024 12:30
Onsite Hours : 02:45


ASEC Report ID : 70894
Name of the Project : Ramp 21 Replacement
Project Location : HJAIA
Weather :
Departure Time : 10/04/2024 15:15
ASEC Technician Name : Solomon Cherie

As requested, our AS Engineering & Consulting LLC representative was on site to observe concrete placement. The following were performed this day:

1) Air content tests, concrete temperature, slump and unit weight were taken for Truck #1 and Truck #3 sampled.

2) One set of seven (7) beams were cast.

All concrete tests were found to be within job specifications.



One set of 7 beams

Kenneth Mosman

Kenneth Mosman

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.