

Date : 01/08/2025  
Project No : 2024C202  
Client Company : CCG  
Arrival Time : 01/08/2025 07:30  
Onsite Hours : 08:45


ASEC Report ID : 75161  
Name of the Project : Old Griffin Rd - Hawthorne Reserve  
Project Location : Dallas  
Weather : Clear sky  
Departure Time : 01/08/2025 16:15  
ASEC Technician Name : Solomon Cherie

Our AS Engineering & Consulting (ASEC) representative arrived on site to observe field activities. The following tasks were performed:

Observed the placement of fill/grading for Lots #27 through #30 today. Compaction tests were performed using a nuclear density gauge. Overall, the results of density testing confirmed that fill compaction met the project and ASTM requirements. Results are attached in separate reports.

An additional compaction test was performed on Lot #63. Backfilling of the sewer line trench between Manhole A12 & A13 was completed today. General probing found the subgrade soils stable.

Please contact us if you have any questions regarding this report or of the density test results.




Picture depicting 12-50 feet backfill building pads



Sewer line backfilled and compacted

Date : 01/08/2025  
Project No : 2024C202  
Client Company : CCG  
Arrival Time : 01/08/2025 07:30  
Onsite Hours : 08:45

ASEC Report ID : 75161  
Name of the Project : Old Griffin Rd - Hawthorne Reserve  
Project Location : Dallas  
Weather : Clear sky  
Departure Time : 01/08/2025 16:15  
ASEC Technician Name : Solomon Cherie



Sewer line trench before complete backfill and compaction

*Kenneth Mosman*

**Kenneth Mosman**

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.