

Date : 11/17/2025  
Project No : 2024C202  
Client Company : CCG  
Arrival Time : 11/17/2025 08:00  
Onsite Hours : 02:30

ASEC Report ID : 87913  
Name of the Project : Old Griffin Rd - Hawthorne Reserve  
Project Location : Dallas  
Weather : Sunny  
Departure Time : 11/17/2025 10:30  
ASEC Technician Name : Clyde Smith

As requested, the site was visited by our AS Engineering and Consulting (ASEC) representative for the purpose of providing quality control inspection and testing services. Visual observation techniques were employed to verify compliance with project drawing/specifications, applicable codes, and materials submittals. The following observations were observed on site this day.

On the above date the writer was on site to observe proof-rolling of subgrade soils for the west half at Hawthorne Grove Lane between Reserve and Laurel. The subgrade was observed using a loaded tandem dump truck. The paving contractor also observed the proof-roll and acknowledged isolated movements and agreed to clip an additional 2" and replace with base stone. ASEC also reminded the contractor of additional areas for repair at the south end of the roadway toward the entrance.

We appreciate the opportunity to be of service to you on this project. If you have any questions regarding this report, please feel free to contact us. We will be more than happy to discuss it with you.



Proof roll of sub grade on Hawthorne and Reserve



Date : 11/17/2025  
Project No : 2024C202  
Client Company : CCG  
Arrival Time : 11/17/2025 08:00  
Onsite Hours : 02:30

ASEC Report ID : 87913  
Name of the Project : Old Griffin Rd - Hawthorne Reserve  
Project Location : Dallas  
Weather : Sunny  
Departure Time : 11/17/2025 10:30  
ASEC Technician Name : Clyde Smith



*Kenneth Mosman*

**Kenneth Mosman**

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.