

Date : 10/17/2024
Project No : 2024C223
Client Company : CWM
Arrival Time : 17:00
Onsite Hours :

ASEC Report ID : 71453
Name of the Project : Concourse E Gate & Ramp 6 North Gate
Project Location : HJAIA
Weather :
Departure Time : 10/17/2024 02:00
ASEC Technician Name : Solomon Cherie

As requested, our AS Engineering & Consulting LLC representative was on site to observe concrete placement. The following were performed this day:

- 1) Moisture tests were taken (for rock and sand materials).
 - 2) Air content tests, concrete temperature, slump and unit weight were taken for Truck #1 and Truck #5 sampled.
 - 3) One set of eleven (11) beams were cast.
 - 4) One set of seven (7) beams were stripped and placed in curing.
 - 5) Cast one set of four (4) 6" x 12" cylinders for low slump/low energy concrete.
- All concrete tests were found to be within job specifications.



Kenneth Mosman

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.