

Date : 04/23/2026
Project No : 2025C149
Client Company : Davidson Homes
Arrival Time : 04/23/2026 8:00
Onsite Hours : 9:00

ASEC Report ID : 94776
Name of the Project : Grove at E. Thompson Mill Rd
Project Location : Buford
Weather : clear and sunny
Departure Time : 04/23/2026 17:00
ASEC Technician Name : Narayana Ganesh Undavalli

Test Date	Test Number	Moisture Content (%)	Dry Density (pcf)	Proctor Number	Max. Dry Density (pcf)	Optimum Moisture (%)	Compaction (%)	Specified Compaction (%)	ASTM Test Method	Pass/Fail
04/23/2026	1	17.3	106.0	2025-022 SP	103.7	16.1	102.2	95	D6938	Pass
Location : Retaining wall 5, Elv/Depth :2 feet										
Comment :										
Tested By : Narayana Ganesh Undavalli Gauge Serial No. : 91487										
04/23/2026	2	16.5	108.2	2025-022 SP	103.7	16.1	104.3	95	D6938	Pass
Location : Retaining wall 5, Elv/Depth :2 feet										
Comment :										
Tested By : Narayana Ganesh Undavalli Gauge Serial No. : 91487										

Remark: Test performed in general accordance with signed referenced ASTM Method.


Kenneth Mosman

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.

Date : 04/23/2026
Project No : 2025C149
Client Company : Davidson Homes
Arrival Time : 04/23/2026 8:00
Onsite Hours : 9:00

ASEC Report ID : 94776
Name of the Project : Grove at E. Thompson Mill Rd
Project Location : Buford
Weather : clear and sunny
Departure Time : 04/23/2026 17:00
ASEC Technician Name : Narayana Ganesh Undavalli

PROCTOR DATA SUMMARY

TEST DATE	PROCTOR ID	MAX DRY DENSITY (pcf)	OPTIMUM MOISTURE (%)	PROCTOR TYPE	SOIL DESCRIPTION
04/22/2025	2025-022 SP	103.7	16.1	Standard	Brown Sandy SILT
04/22/2025	2025-023 SP	103.5	18.9	Standard	Red Sandy CLAY
04/27/2026	2026-105	96.4	18.1	Standard	Light brown sandy silt
05/18/2026	2026-135	96.9	13.8	Standard	Light brown sandy silt