

Date : 05/28/2026
Project No : 2025C214
Client Company : Artisan
Arrival Time : 05/28/2026 08:00
Onsite Hours : 04:00

ASEC Report ID : 94848
Name of the Project : NW Unit 4 BRIDGE (Materials Testing)
Project Location : Dallas
Weather : cloudy
Departure Time : 05/28/2026 12:00
ASEC Technician Name : Clyde Smith

As requested, the site was visited by our AS Engineering and Consulting (ASEC) representative for the purpose of providing quality control inspection and testing services. Visual observation techniques were employed to verify compliance with project drawing/specifications, applicable codes, and materials submittals. The following observations were observed on site this day.

On the above date our representative made a site visit to the above site to observe subgrade conditions for the crane pad and bridge wall backfill. Subgrade repairs are recommended for crane pad stabilization.

We appreciate the opportunity to be of service to you on this project. If you have any questions regarding this report, please feel free to contact us. We will be more than happy to discuss it with you.



Erosion deficiencies



Erosion at wall backfill



Recommended subgrade repair at crane pad

Date : 05/28/2026
Project No : 2025C214
Client Company : Artisan
Arrival Time : 05/28/2026 08:00
Onsite Hours : 04:00

ASEC Report ID : 94848
Name of the Project : NW Unit 4 BRIDGE (Materials Testing)
Project Location : Dallas
Weather : cloudy
Departure Time : 05/28/2026 12:00
ASEC Technician Name : Clyde Smith



Kenneth Mosman

Kenneth Mosman

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.