

Date : 06/05/2026
Project No : 2025C216
Client Company : Artisan
Arrival Time : 06/05/2026 07:30
Onsite Hours : 04:00

ASEC Report ID : 95135
Name of the Project : NW (Lots) Unit 4 PH 1A & 1B
Project Location : Dallas
Weather : Sunny
Departure Time : 06/05/2026 11:30
ASEC Technician Name : Clyde Smith

As requested, the site was visited by our AS Engineering and Consulting (ASEC) representative for the purpose of providing quality control inspection and testing services. Visual observation techniques were employed to verify compliance with project drawing/specifications, applicable codes, and materials submittals. The following observations were observed on site this day.

On the above date our representative was on site to observe the paving contractor NWGP place a 19 mm asphalt binder mix at Nature Walk Parkway between sanitary sewer manholes #9 and 11. The contractor placed tack coat to the existing curb edges and previous edge of asphalt. The contractor placed approximately 180 tons of binder mix today. The writer also performed density checks and temperature checks during asphalt placement.

1. Temperature checks: 295, 305 and 315 degrees (Fahrenheit).

2. Density checks: 137.4, 138.2, 135.5, 137.7, 139.1 and 136.6 (all in pcf).

We appreciate the opportunity to be of service to you on this project. If you have any questions regarding this report, please feel free to contact us. We will be more than happy to discuss it with you.



Density checks on in place binder mix



Date : 06/05/2026
Project No : 2025C216
Client Company : Artisan
Arrival Time : 06/05/2026 07:30
Onsite Hours : 04:00

ASEC Report ID : 95135
Name of the Project : NW (Lots) Unit 4 PH 1A & 1B
Project Location : Dallas
Weather : Sunny
Departure Time : 06/05/2026 11:30
ASEC Technician Name : Clyde Smith



Compacting binder mix



Tacked curb edges



Asphalt paving



Date : 06/05/2026
Project No : 2025C216
Client Company : Artisan
Arrival Time : 06/05/2026 07:30
Onsite Hours : 04:00

ASEC Report ID : 95135
Name of the Project : NW (Lots) Unit 4 PH 1A & 1B
Project Location : Dallas
Weather : Sunny
Departure Time : 06/05/2026 11:30
ASEC Technician Name : Clyde Smith



Kenneth Mosman

Kenneth Mosman

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.