

Date : 09/16/2025
Project No : 2025C224
Client Company : C. W. MATTHEWS CONTRACTING CO., INC.
Arrival Time : 09/16/2025 16:00
Onsite Hours : 08:00

ASEC Report ID : 86017
Name of the Project : PDK Airport - RUNWAY 3R-21L KEEL
REPLACEMENT
Project Location : PDK AIRPORT, DEKALB County, GA
Weather : N/A
Departure Time : 09/17/2025 00:00
ASEC Technician Name : Solomon Cherie

At the request of the client's representative, AS ENGINEERING AND CONSULTING, LLC (ASEC) representative Amin Azimi visited the job site to observe and monitor the contractor's work activities from a quality assurance standpoint. The purpose of the visit was to verify compliance with project drawings, specifications, applicable codes, and approved material submittals, as well as to conduct quality control testing in accordance with project requirements.

During the night shift 540 cubic yards of concrete was placed at the PDK airport. The concrete was processed from the temporary batch plant of CWM located on the PDK airport premises.

Three (3) air content, slump and unit weight tests were performed along with the recording of outside and concrete temperatures. All test results were found to be within project specifications.

Moreover, data loggers were placed inside the concrete for future temperature tests and monitoring.

We appreciate the opportunity to be of service on this project. Should you have any questions regarding this report, please do not hesitate to contact us. We would be pleased to discuss our findings further.



Picture depicting the entire pouring for the day



Picture showing how the data loggers installed at specific sites.

Kenneth Mosman

Kenneth Mosman

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.