

Date : 09/18/2025
Project No : 2025C224
Client Company : C. W. MATTHEWS CONTRACTING CO., INC.
Arrival Time : 09/18/2025 16:00
Onsite Hours : 08:00

ASEC Report ID : 86028
Name of the Project : PDK Airport - RUNWAY 3R-21L KEEL
REPLACEMENT
Project Location : PDK AIRPORT, DEKALB County, GA
Weather : N/A
Departure Time : 09/19/2025 00:00
ASEC Technician Name : Solomon Cherie

At the request of the client's representative, AS ENGINEERING AND CONSULTING, LLC (ASEC) representative Amin Azimi visited the job site to observe and monitor the contractor's work activities from a quality assurance standpoint. The purpose of the visit was to verify compliance with project drawings, specifications, applicable codes, and approved material submittals, as well as to conduct quality control testing in accordance with project requirements.


Concrete placement for Runway 3R-21L was performed throughout the night. Approximately 800 cubic yards of concrete was placed and four rounds of field tests were performed. All tests for slump, concrete temperature, air temperature, air content and unit weight were found to be within job specification range.

Moreover, three data loggers were installed at regular distance for temperature controlling of the concrete.

We appreciate the opportunity to be of service on this project. Should you have any questions regarding this report, please do not hesitate to contact us. We would be pleased to discuss our findings further.



The concrete crews and the machineries



Picture depicting Runway 3R-2L at concrete
poure

Date : 09/18/2025
Project No : 2025C224
Client Company : C. W. MATTHEWS CONTRACTING CO., INC.
Arrival Time : 09/18/2025 16:00
Onsite Hours : 08:00

ASEC Report ID : 86028
Name of the Project : PDK Airport - RUNWAY 3R-21L KEEL
REPLACEMENT
Project Location : PDK AIRPORT, DEKALB County, GA
Weather : N/A
Departure Time : 09/19/2025 00:00
ASEC Technician Name : Solomon Cherie



Picture depicting one of the data loggers buried in the concrete

Kenneth Mosman

Kenneth Mosman

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.