

Date : 04/28/2021  
Project No : 2020C002  
Client Company : Toll Bros. Inc.  
Arrival Time : 04/28/2021 09:00  
Onsite Hours : 08:00

ASEC Report ID : 15493  
Name of the Project : Northfields at Polo Fields  
Project Location : 4805 Pittman Road, Forsyth County, Georgia  
Weather : Sunny  
Departure Time : 04/28/2021 17:00  
ASEC Technician Name : Andrew McCullough

| Test Date                                                                                   | Test Number | Moisture Content (%) | Dry Density (pcf) | Proctor Number | Max. Dry Density (pcf) | Optimum Moisture (%) | Compaction (%) | Specified Compaction (%) | ASTM Test Method | Pass/Fail |
|---------------------------------------------------------------------------------------------|-------------|----------------------|-------------------|----------------|------------------------|----------------------|----------------|--------------------------|------------------|-----------|
| 04/28/2021                                                                                  | 1           | 24.9                 | 96.6              | P-1            | 97.7                   | 22.2                 | 98.9           | 95                       | D2937            | Pass      |
| Location : Front of lot #30, Elv/Depth :1094<br>Comment :<br>Tested By : Andrew McCullough  |             |                      |                   |                |                        |                      |                |                          |                  |           |
| 04/28/2021                                                                                  | 2           | 24.2                 | 95.2              | P-1            | 97.7                   | 22.2                 | 97.4           | 95                       | D2937            | Pass      |
| Location : Rear of lot #30, Elv/Depth :1096<br>Comment :<br>Tested By : Andrew McCullough   |             |                      |                   |                |                        |                      |                |                          |                  |           |
| 04/28/2021                                                                                  | 3           | 24.6                 | 97.0              | P-1            | 97.7                   | 22.2                 | 99.3           | 95                       | D2937            | Pass      |
| Location : Center of lot #30, Elv/Depth :1097<br>Comment :<br>Tested By : Andrew McCullough |             |                      |                   |                |                        |                      |                |                          |                  |           |

**Remark:** Test performed in general accordance with signed referenced ASTM Method.



**Ramchandra R. Mogulla**  
**GA P.E. 036021**  
**Senior Engineer**

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.

Date : 04/28/2021  
Project No : 2020C002  
Client Company : Toll Bros. Inc.  
Arrival Time : 04/28/2021 09:00  
Onsite Hours : 08:00

ASEC Report ID : 15493  
Name of the Project : Northfields at Polo Fields  
Project Location : 4805 Pittman Road, Forsyth County, Georgia  
Weather : Sunny  
Departure Time : 04/28/2021 17:00  
ASEC Technician Name : Andrew McCullough

---

**PROCTOR DATA SUMMARY**

| TEST DATE  | PROCTOR ID | MAX DRY DENSITY<br>(pcf) | OPTIMUM MOISTURE (%) | PROCTOR TYPE | SOIL DESCRIPTION       |
|------------|------------|--------------------------|----------------------|--------------|------------------------|
| 02/26/2021 | P-1        | 97.7                     | 22.2                 | Standard     | Light Brown Silty CLAY |