

Date : 05/08/2021
Project No : 2020C002
Client Company : Toll Bros. Inc.
Arrival Time : 05/08/2021 08:00
Onsite Hours : 08:00

ASEC Report ID : 15765
Name of the Project : Northfields at Polo Fields
Project Location : 4805 Pittman Road, Forsyth County, Georgia
Weather : Sunny
Departure Time : 05/08/2021 16:00
ASEC Technician Name : Andrew McCullough

Test Date	Test Number	Moisture Content (%)	Dry Density (pcf)	Proctor Number	Max. Dry Density (pcf)	Optimum Moisture (%)	Compaction (%)	Specified Compaction (%)	ASTM Test Method	Pass/Fail
05/08/2021	1	24.1	116.5	P-1	97.7	22.2	96.1	95	D6938	Pass
Location : 20' West of MH A 7, Elv/Depth :+2										
Comment :										
Tested By : Andrew McCullough Gauge Serial No. : 29588										
05/09/2021	2	23.2	96.0	P-1	97.7	22.2	98.3	95	D6938	Pass
Location : 50' West of MH A7, Elv/Depth :+3										
Comment :										
Tested By : Andrew McCullough Gauge Serial No. : 29588										
05/08/2021	3	24.3	95.3	P-1	97.7	22.2	97.5	95	D6938	Pass
Location : 40' West of MH A7, Elv/Depth :+4										
Comment :										
Tested By : Andrew McCullough Gauge Serial No. : 29588										
05/08/2021	4	23.5	95.8	P-1	97.7	22.2	98.1		D6938	Pass
Location : 60' West of MH A7, Elv/Depth :+5										
Comment :										
Tested By : Andrew McCullough Gauge Serial No. : 29588										

Remark: Test performed in general accordance with signed referenced ASTM Method.



Ramchandra R. Mogulla
GA P.E. 036021
Senior Engineer

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.

Date : 05/08/2021
Project No : 2020C002
Client Company : Toll Bros. Inc.
Arrival Time : 05/08/2021 08:00
Onsite Hours : 08:00

ASEC Report ID : 15765
Name of the Project : Northfields at Polo Fields
Project Location : 4805 Pittman Road, Forsyth County, Georgia
Weather : Sunny
Departure Time : 05/08/2021 16:00
ASEC Technician Name : Andrew McCullough

PROCTOR DATA SUMMARY

TEST DATE	PROCTOR ID	MAX DRY DENSITY (pcf)	OPTIMUM MOISTURE (%)	PROCTOR TYPE	SOIL DESCRIPTION
02/26/2021	P-1	97.7	22.2	Standard	Light Brown Silty CLAY